



APPD.				
CERT.				
CHKD.	A.Ashery			
DESCRIPTION	Issued For Approval			
BY	Wael			
DATE	30-04-2020			
NO.	00			
REVISIONS				
DRAWN				
BY	Wael			
DATE	April 2020			
CHECKED				
BY	A.Ashery			
DATE	April 2020			
OPRG. DEPT.				
BY				
DATE				
ENG'G. DEPT.				
BY				
DATE				
CERTIFIED				
BY				
DATE				

* LENGTH TABLE OF THE BOLT													
SIZE OF BOLT	L	LT	L-S	ALLOWABLE CLAMPING			THICKNESS			EXT.			REMARKS
							WASHER	NUT	PAL				
M16	40	31	9	5	-	9	4	15	5	7	-	11	
	45	31	14	10	-	14	4	15	5	7	-	11	
	50	31	19	15	-	19	4	15	5	7	-	11	
	55	31	24	20	-	24	4	15	5	7	-	11	
	60	31	29	25	-	29	4	15	5	7	-	11	
	65	31	34	30	-	34	4	15	5	7	-	11	
	70	31	39	35	-	39	4	15	5	7	-	11	
	75	31	44	40	-	44	4	15	5	7	-	11	
	80	31	49	45	-	49	4	15	5	7	-	11	
	85	31	54	50	-	54	4	15	5	7	-	11	
	90	31	59	55	-	59	4	15	5	7	-	11	
	95	31	64	60	-	64	4	15	5	7	-	11	
	100	31	69	65	-	69	4	15	5	7	-	11	
M20	50	36	14	10	-	14	4	18	6	8	-	12	
	55	36	19	15	-	19	4	18	6	8	-	12	
	60	36	24	20	-	24	4	18	6	8	-	12	
	65	36	29	25	-	29	4	18	6	8	-	12	
	70	36	34	30	-	34	4	18	6	8	-	12	
	75	36	39	35	-	39	4	18	6	8	-	12	
	80	36	44	40	-	44	4	18	6	8	-	12	
	85	36	49	45	-	49	4	18	6	8	-	12	
	90	36	54	50	-	54	4	18	6	8	-	12	
	95	36	59	55	-	59	4	18	6	8	-	12	
	100	36	64	60	-	64	4	18	6	8	-	12	
	105	36	69	65	-	69	4	18	6	8	-	12	
M24	50	41	9	5	-	9	4	21	7	9	-	13	
	55	41	14	10	-	14	4	21	7	9	-	13	
	60	41	19	15	-	19	4	21	7	9	-	13	
	65	41	24	20	-	24	4	21	7	9	-	13	
	70	41	29	25	-	29	4	21	7	9	-	13	
	75	41	34	30	-	34	4	21	7	9	-	13	
	80	41	39	35	-	39	4	21	7	9	-	13	
	85	41	44	40	-	44	4	21	7	9	-	13	
	90	41	49	45	-	49	4	21	7	9	-	13	

AS BUILT BY	NCC	DATE :	30-04-2020		DRAWING CONTROL	SHEET EE-600832	
DRAWING TITLE			INDEX	PLANT NO.	DRAWING NO.	SHEET NO.	REV. NO.
<u>BOLTS GRIP CHART FOR M16, M20 & M24</u>			A	HA322	EE-601070	02 OF 02	00
<u>380kV OHTL BETWEEN SHEDGUM-2 380/115kV BSP AND ENERGY INDUSTRIAL CITY (EIC) 380/115kV BSP</u>							
ABQAIQ		SAUDI ARABIA		JOB ORDER NO. 3-1813001.04		CONTRACT NO. 4400011875	

